



number	100524/01	Replaces	--
Date of issue	13-12-2018	Issued first	13-12-2018
		Report number	180900836

Declaration
**regarding the efficiency of a shower heat
 recovery unit**

DECLARATION OF KIWA

This declaration is based on a single examination by Kiwa on a product supplied by

Dutch Solar Systems B.V.

This declaration does not pass a judgment on other products supplied by the manufacturer.

The product was tested according the procedure according annex B of the NEN 7120+C2/A1:2017.

DSS/Bries WWHRS SP-5(CW3) 2100mm

class	Flow (l/min)	Volume (l)	Efficiency (%)	Pressure drop (bar)
2	5.8	47	68.5	0.20
3	9.2	73	65.5	0.44

DSS/Bries WWHRS SP-5(CW4) 2100mm

class	Flow (l/min)	Volume (l)	Efficiency (%)	Pressure drop (bar)
--	11	88	63.2	0.53
4,5,6	12.5	100	62.6	0.67

DSS/Bries WWHRS SP-5M(Comfort) 2100mm

class	Flow (l/min)	Volume (l)	Efficiency (%)	Pressure drop (bar)
4,5,6	12.5	100	52.6	0.13
--	15.0	120	50.9	0.18

Allard Slomp
 Productmanager

Kiwa Nederland B.V.

